



To,

Reference: Bidding Document for Tender No.: RGHPL-C-01/2074/075

**“Supply, Delivery and Installation of Deep Tubewell and Water Supply System from Power House site at Tilkane to Camp area at Rakhu Pipe”**

**Amendment No. 1**

**“Amendment No. 1” is hereby issued pursuant to above referred Document**

1. **Clause 2.8 (iii), Section III, Part I**  
Replace with the following.

Item No.	Description of Item	Minimum Criteria to be met
1	Steel Seamless Pipe, Submersible Pump	iii) Must submit ISO 9001 (including Design) of Seamless Pipe and Submersible Pump.

2. **Bill of Quantities Table, Section VI, Part II (Page 115)**  
Delete the “Item 10 Pumping Test by Suitable Pump, Item 11 Water Quality Test, Item 12 Submission of Well Completion, Pumping Test and Water Quality Test Report, Item 13 Filter Unit with ,maximum flow rate of 10m<sup>3</sup>/s (Supply and Installation Complete)
3. **Bill of Quantities Table, Section VI, Part II (Page 114)**  
Replace the Description of Item no. 14 by “Filter Unit with, maximum flow rate of 10m<sup>3</sup>/h (Supply and Installation Complete with Chlorine Dosing System and Pressure Sand Filter)”
4. **Specifications, Section V, Part II (Page 103)**  
Replace “Part A: Specification for Sanitary Works” by “Part B: Specification for Sanitary Works.”
5. **Scope of Works, Section V, Part II (Page 4)**  
Add new clause as, “1.1.7 In case of failure to deliver 3 LPS of water upto the depth of 100m, 50% payment shall be made for Pilot Hole Drilling and contractor shall propose new drilling point to achieve 3LPS with consent of Employer”
6. **Clause 1.6, Part B: Specifications for Sanitary Works, Section V, Part II (Page 105)**  
Replace Hydrostatic pressure of 10kg/sq.cm by 40kg/sq.cm.
7. **ITB 7.1, ITB 22.1 and ITB 25.1 of Section II, Part I**  
**GCC 1.1 (q), Section VIII, Part III and Invitation for Bids**  
Replace Telephone No. by +977-01-6610646/6620024.

Shreeram Raj Pandey

Managing Director